

Mr Paddy Larkin  
Moyle Interconnector Ltd  
First Floor the Arena Building  
85 Ormeau Rd  
Belfast  
BT7 1SH

17 January 2011

**Access Arrangements – Moyle Interconnector**

Dear Paddy,

I write in relation to the email sent by Paul McGuckin (received on 17 January 2011) requesting the amendment of Moyle's Access Arrangements to reflect the expansion of Moyle's export capacity from 80 MW to 295MW, these new export capacity figures have also been confirmed by SONI (email received from Dick Lewis on 17 January 2011) The email also suggested the terms of the amendment, which were as follows:

Section 3.1 of which currently states:

*'Maximum Export (West-East) ATC - 80MW at all times.'*

This shall now read

*'Maximum Export (West-East) ATC - 287MW for the period commencing 2nd May and ending immediately before 29th August. 295MW at all other times''*

The Utility Regulator thereby approves your request and determines that the above amendment should be implemented on Moyle's Access Arrangements at your earliest convenience.

Yours Sincerely



**Juliet Corbett**  
**Manager, Wholesale Market**